



PUBLIC WORKS
Water Division

IEPA - Rockford Regional Office
4302 N. Main St
Rockford, IL 61103

March 5, 2024

Re: Monthly Operating Reports: City of Sycamore – IL0370550

Please find the enclosed operating reports for the City of Sycamore, IL.

- Monthly Operating Reports
- Water Quality Control
- Monthly Chlorine Distribution

Should you have any questions or concerns, please contact me at (815) 895-3545 or by email at maanderson@cityofsycamore.com

Sincerely Yours,

Matt Anderson
City of Sycamore
Director of Public Works

City of Sycamore

Water Division

Monthly Operations Report

February 2024

DATE	HOURS RUN	PUMPAGE (WELL)	PUMPAGE (WRT)	WELL (gpm)	WRT (gpm)	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	26	1,573,000	1,559,000	1,008.33	999.36	63	4.80	14	0.79	62	0.16
2/2/2024	40	2,165,000	2,148,000	902.08	895.00	82	4.54	22	0.82	95	0.18
2/3/2024	28	1,483,000	1,481,000	882.74	881.55	60	4.85	15	0.82	63	0.17
2/4/2024	30	1,571,000	1,586,000	872.78	881.11	66	5.04	19	0.87	65	0.17
2/5/2024	32	1,770,000	1,767,000	921.88	920.31	70	4.74	19	0.84	76	0.18
2/6/2024	29	1,606,000	1,603,000	922.99	921.26	64	4.78	15	0.80	64	0.16
2/7/2024	34	1,833,000	1,831,000	898.53	897.55	72	4.71	22	0.87	80	0.18
2/8/2024	36	1,954,000	1,955,000	904.63	905.09	78	4.79	20	0.82	81	0.17
2/9/2024	31	1,593,000	1,584,000	856.45	851.61	61	4.59	17	0.83	71	0.18
2/10/2024	31	1,703,000	1,698,000	915.59	912.90	68	4.79	18	0.83	73	0.17
2/11/2024	28	1,518,000	1,524,000	903.57	907.14	63	4.98	15	0.81	61	0.16
2/12/2024	40	2,132,000	2,135,000	888.33	889.58	91	5.12	25	0.86	84	0.16
2/13/2024	35	1,837,000	1,840,000	874.76	876.19	81	5.29	22	0.87	76	0.17
2/14/2024	27	1,477,000	1,473,000	911.73	909.26	62	5.03	15	0.82	60	0.17
2/15/2024	35	2,094,000	2,089,000	997.14	994.76	76	4.35	20	0.80	80	0.16
2/16/2024	30	1,636,000	1,642,000	908.89	912.22	69	5.06	13	0.76	64	0.16
2/17/2024	32	1,859,000	1,851,000	968.23	964.06	73	4.71	21	0.85	78	0.17
2/18/2024	27	1,647,000	1,650,000	1,016.67	1,018.52	65	4.73	15	0.79	63	0.16
2/19/2024	30	1,685,000	1,681,000	936.11	933.89	67	4.77	16	0.80	69	0.17
2/20/2024	31	1,740,000	1,738,000	935.48	934.41	69	4.75	18	0.83	71	0.17
2/21/2024	37	2,105,000	2,097,000	948.20	944.59	79	4.50	19	0.79	91	0.18
2/22/2024	26	1,336,000	1,343,000	856.41	860.90	55	4.94	14	0.83	56	0.17
2/23/2024	43	2,191,000	2,176,000	849.22	843.41	85	4.65	22	0.82	106	0.20
2/24/2024	26	1,344,000	1,345,000	861.54	862.18	55	4.91	14	0.83	54	0.16
2/25/2024	32	1,773,000	1,771,000	923.44	922.40	67	4.53	20	0.85	83	0.19
2/26/2024	29	1,517,000	1,504,000	871.84	864.37	57	4.51	15	0.81	68	0.18
2/27/2024	38	2,052,000	2,053,000	900.00	900.44	78	4.56	21	0.82	87	0.17
2/28/2024	32	1,672,000	1,666,000	870.83	867.71	63	4.52	18	0.84	72	0.18
2/29/2024	34	1,876,000	1,881,000	919.61	922.06	73	4.67	21	0.85	83	0.18
TOTALS											
MONTH	929.0	50,742,000	50,671,000	910.33	909.06	2,012	4.75	525	0.83	2,136	0.17
YEAR	1,875.0	103,008,000	102,939,000	915.63	915.01	4,078	4.75	1,057	0.82	4,285	0.17

City of Sycamore - Facility #0370550
WELL 6

DATE	HOURS RUN	WELL6 RAW	WELL 6 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	12	659,000	915.28	648,000	900.00	25	4.55	4	0.64	27	0.17
2/2/2024	6	300,000	833.33	295,000	819.44	11	4.40	2	0.65	12	0.16
2/3/2024	8	413,000	860.42	407,000	847.92	15	4.35	2	0.61	17	0.17
2/4/2024	8	420,000	875.00	414,000	862.50	15	4.28	3	0.67	18	0.17
2/5/2024	7	406,000	966.67	399,000	950.00	15	4.43	3	0.63	17	0.17
2/6/2024	7	376,000	895.24	370,000	880.95	15	4.78	2	0.62	14	0.15
2/7/2024	10	536,000	893.33	528,000	880.00	20	4.47	4	0.63	22	0.17
2/8/2024	12	640,000	888.89	631,000	876.39	24	4.50	5	0.69	27	0.17
2/9/2024	4	168,000	700.00	164,000	683.33	7	5.00	1	0.64	7	0.17
2/10/2024	8	446,000	929.17	439,000	914.58	16	4.30	2	0.60	18	0.16
2/11/2024	8	432,000	900.00	425,000	885.42	17	4.72	3	0.66	18	0.17
2/12/2024	8	426,000	887.50	420,000	875.00	16	4.50	3	0.67	17	0.16
2/13/2024	3	142,000	788.89	140,000	777.78	5	4.22	1	0.67	6	0.17
2/14/2024	14	745,000	886.90	733,000	872.62	27	4.35	5	0.66	30	0.16
2/15/2024	6	342,000	950.00	337,000	936.11	12	4.21	2	0.63	14	0.17
2/16/2024	10	493,000	821.67	485,000	808.33	19	4.62	3	0.64	20	0.17
2/17/2024	9	500,000	925.93	491,000	909.26	19	4.56	6	0.81	24	0.20
2/18/2024	1	35,000	583.33	35,000	583.33	1	3.43	0	0.47	1	0.12
2/19/2024	8	456,000	950.00	449,000	935.42	17	4.47	3	0.65	20	0.18
2/20/2024	9	469,000	868.52	462,000	855.56	17	4.35	4	0.71	20	0.17
2/21/2024	12	654,000	908.33	643,000	893.06	23	4.22	5	0.68	30	0.19
2/22/2024	11	557,000	843.94	549,000	831.82	20	4.31	5	0.72	25	0.18
2/23/2024	18	980,000	907.41	964,000	892.59	38	4.65	8	0.70	46	0.19
2/24/2024	11	565,000	856.06	557,000	843.94	21	4.46	5	0.72	24	0.17
2/25/2024	8	464,000	966.67	456,000	950.00	16	4.13	4	0.71	26	0.23
2/26/2024	4	187,000	779.17	184,000	766.67	7	4.49	1	0.62	8	0.17
2/27/2024	14	709,000	844.05	698,000	830.95	25	4.23	6	0.71	31	0.18
2/28/2024	10	512,000	853.33	501,000	835.00	18	4.22	4	0.69	23	0.18
2/29/2024	6	352,000	977.78	350,000	972.22	12	4.09	3	0.71	16	0.19
TOTALS											
MONTH	252	13,384,000	885.19	13,174,000	871.30	493	4.49	99	0.80	578	0.18
YEAR	484	25,757,000	886.95	25,355,000	873.11	953	4.51	187	0.79	1,116	0.18

**City of Sycamore - Facility #0370550
WELL 7**

DATE	HOURS RUN	WELL 7 RAW	WELL 7 GPM	Finished PUMPED	Finished GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/2/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/3/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/4/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/5/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/6/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/7/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/8/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/9/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/10/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/11/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/12/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/13/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/14/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/15/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/16/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/17/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/18/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/19/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/20/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/21/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/22/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/23/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/24/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/25/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/26/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/27/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/28/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/29/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
TOTALS											
MONTH	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
YEAR	82	4,595,000	933.94	4,595,000	933.94	174	4.54	35	0.80	165	0.15

**City of Sycamore - Facility #0370550
WELL 8**

DATE	HOURS RUN	WELL 8 RAW	WELL 8 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	7	487,000	1,159.52	482,000	1,147.62	18	4.43	4	0.73	20	0.17
2/2/2024	18	1,192,000	1,103.70	1,178,000	1,090.74	44	4.43	11	0.76	48	0.16
2/3/2024	6	393,000	1,091.67	388,000	1,077.78	15	4.58	4	0.78	16	0.17
2/4/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/5/2024	8	556,000	1,158.33	549,000	1,143.75	20	4.31	5	0.75	22	0.16
2/6/2024	11	691,000	1,046.97	684,000	1,036.36	26	4.51	6	0.74	28	0.17
2/7/2024	8	438,000	912.50	433,000	902.08	16	4.38	5	0.82	21	0.20
2/8/2024	6	447,000	1,241.67	442,000	1,227.78	16	4.29	4	0.75	19	0.17
2/9/2024	12	738,000	1,025.00	730,000	1,013.89	27	4.39	7	0.76	30	0.17
2/10/2024	8	544,000	1,133.33	538,000	1,120.83	21	4.63	5	0.76	22	0.16
2/11/2024	3	197,000	1,094.44	195,000	1,083.33	6	3.65	1	0.64	8	0.17
2/12/2024	9	591,000	1,094.44	584,000	1,081.48	26	5.27	6	0.78	24	0.17
2/13/2024	10	693,000	1,155.00	686,000	1,143.33	33	5.71	6	0.74	28	0.16
2/14/2024	2	143,000	1,191.67	140,000	1,166.67	6	5.03	2	0.89	6	0.17
2/15/2024	10	648,000	1,080.00	642,000	1,070.00	23	4.26	6	0.76	26	0.16
2/16/2024	3	189,000	1,050.00	187,000	1,038.89	7	4.44	1	0.65	7	0.15
2/17/2024	7	495,000	1,178.57	489,000	1,164.29	19	4.60	5	0.78	20	0.16
2/18/2024	10	668,000	1,113.33	660,000	1,100.00	23	4.13	6	0.75	25	0.15
2/19/2024	7	428,000	1,019.05	423,000	1,007.14	15	4.20	4	0.76	17	0.16
2/20/2024	7	452,000	1,076.19	447,000	1,064.29	17	4.51	5	0.81	17	0.15
2/21/2024	9	594,000	1,100.00	588,000	1,088.89	22	4.44	5	0.73	24	0.16
2/22/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/23/2024	3	236,000	1,311.11	233,000	1,294.44	9	4.57	2	0.74	9	0.16
2/24/2024	3	172,000	955.56	170,000	944.44	7	4.88	1	0.66	7	0.17
2/25/2024	6	415,000	1,152.78	410,000	1,138.89	15	4.33	4	0.77	16	0.16
2/26/2024	14	891,000	1,060.71	881,000	1,048.81	33	4.44	9	0.78	35	0.16
2/27/2024	7	490,000	1,166.67	485,000	1,154.76	19	4.65	5	0.78	21	0.17
2/28/2024	6	402,000	1,116.67	397,000	1,102.78	14	4.18	3	0.71	15	0.15
2/29/2024	8	515,000	1,072.92	509,000	1,060.42	18	4.19	5	0.77	20	0.16
TOTALS											
MONTH	208	13,705,000	1,098.16	13550000	1,085.74	515	4.56	127	0.84	551	0.17
YEAR	376	24,839,000	1,101.02	24,558,000	1,088.56	932	4.55	224	0.83	1,004	0.17

City of Sycamore - Facility #0370550
WELL 9

DATE	HOURS RUN	WELL 9 RAW	WELL 9 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	7	427,000	1,016.67	429,000	1,021.43	20	5.62	6	0.81	15	0.14
2/2/2024	2	118,000	983.33	120,000	1,000.00	6	6.10	1	0.65	4	0.14
2/3/2024	7	393,000	935.71	402,000	957.14	19	5.80	5	0.76	14	0.15
2/4/2024	17	927,000	908.82	948,000	929.41	43	5.56	13	0.80	35	0.15
2/5/2024	7	391,000	930.95	402,000	957.14	19	5.83	5	0.76	14	0.15
2/6/2024	8	438,000	912.50	448,000	933.33	19	5.20	5	0.73	16	0.15
2/7/2024	8	469,000	977.08	480,000	1,000.00	21	5.37	7	0.82	17	0.15
2/8/2024	12	628,000	872.22	643,000	893.06	28	5.35	8	0.76	23	0.15
2/9/2024	2	120,000	1,000.00	123,000	1,025.00	5	5.00	1	0.64	3	0.10
2/10/2024	6	365,000	1,013.89	373,000	1,036.11	18	5.91	5	0.79	13	0.15
2/11/2024	13	703,000	901.28	718,000	920.51	32	5.46	9	0.77	25	0.14
2/12/2024	12	672,000	933.33	688,000	955.56	32	5.71	9	0.78	24	0.15
2/13/2024	9	499,000	924.07	511,000	946.30	23	5.53	7	0.80	19	0.16
2/14/2024	8	455,000	947.92	466,000	970.83	24	6.32	6	0.78	17	0.15
2/15/2024	5	266,000	886.67	272,000	906.67	11	4.96	3	0.72	7	0.11
2/16/2024	12	698,000	969.44	714,000	991.67	33	5.67	6	0.65	27	0.16
2/17/2024	5	245,000	816.67	252,000	840.00	12	5.87	4	0.86	9	0.15
2/18/2024	8	465,000	968.75	476,000	991.67	23	5.93	5	0.71	17	0.15
2/19/2024	7	385,000	916.67	393,000	935.71	19	5.92	5	0.77	14	0.15
2/20/2024	7	410,000	976.19	420,000	1,000.00	19	5.56	5	0.75	16	0.16
2/21/2024	8	441,000	918.75	450,000	937.50	19	5.17	5	0.73	17	0.16
2/22/2024	10	569,000	948.33	584,000	973.33	26	5.48	7	0.75	20	0.14
2/23/2024	4	206,000	858.33	210,000	875.00	9	5.24	2	0.68	8	0.16
2/24/2024	9	492,000	911.11	503,000	931.48	23	5.61	7	0.80	18	0.15
2/25/2024	8	464,000	966.67	475,000	989.58	20	5.17	6	0.77	17	0.15
2/26/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/27/2024	12	669,000	929.17	686,000	952.78	26	4.66	8	0.74	24	0.15
2/28/2024	8	432,000	900.00	442,000	920.83	18	5.00	6	0.79	15	0.14
2/29/2024	10	575,000	958.33	588,000	980.00	26	5.42	7	0.75	22	0.16
TOTALS											
MONTH	231	12922000	932.32	13216000	953.54	593	5.38	163	0.70	470	0.14
YEAR	467	26,145,000	933.08	26,759,000	955.00	1,186	5.31	335	0.71	928	0.14

City of Sycamore - Facility #0370550

WELL 10

DATE	HOURS RUN	WELL 10 RAW	WELL 10 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
2/1/2024	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
2/2/2024	14	555,000	660.71	555,000	660.71	21	4.54	8	0.86	31	0.23
2/3/2024	7	284,000	676.19	284,000	676.19	11	4.64	4	0.85	16	0.23
2/4/2024	5	224,000	746.67	224,000	746.67	8	4.28	3	0.83	12	0.22
2/5/2024	10	417,000	695.00	417,000	695.00	16	4.60	6	0.86	23	0.22
2/6/2024	3	101,000	561.11	101,000	561.11	4	4.75	2	1.01	6	0.24
2/7/2024	8	390,000	812.50	390,000	812.50	15	4.61	6	0.88	20	0.21
2/8/2024	6	239,000	663.89	239,000	663.89	10	5.02	3	0.81	12	0.20
2/9/2024	13	567,000	726.92	567,000	726.92	22	4.65	8	0.85	31	0.22
2/10/2024	9	348,000	644.44	348,000	644.44	13	4.48	6	0.94	20	0.23
2/11/2024	4	186,000	775.00	186,000	775.00	8	5.16	2	0.76	10	0.22
2/12/2024	11	443,000	671.21	443,000	671.21	17	4.60	7	0.90	19	0.17
2/13/2024	13	503,000	644.87	503,000	644.87	20	4.77	8	0.90	23	0.19
2/14/2024	3	134,000	744.44	134,000	744.44	5	4.47	2	0.87	7	0.21
2/15/2024	14	838,000	997.62	838,000	997.62	30	4.29	9	0.76	33	0.16
2/16/2024	5	256,000	853.33	256,000	853.33	10	4.68	3	0.78	10	0.16
2/17/2024	11	619,000	937.88	619,000	937.88	23	4.46	6	0.73	25	0.16
2/18/2024	8	479,000	997.92	479,000	997.92	18	4.51	4	0.69	20	0.17
2/19/2024	8	416,000	866.67	416,000	866.67	16	4.61	4	0.73	18	0.18
2/20/2024	8	409,000	852.08	409,000	852.08	16	4.69	4	0.73	18	0.18
2/21/2024	8	416,000	866.67	416,000	866.67	15	4.32	4	0.73	20	0.20
2/22/2024	5	210,000	700.00	210,000	700.00	9	5.14	2	0.72	11	0.21
2/23/2024	18	769,000	712.04	769,000	712.04	29	4.52	10	0.82	43	0.23
2/24/2024	3	115,000	638.89	115,000	638.89	4	4.17	1	0.70	5	0.18
2/25/2024	10	430,000	716.67	430,000	716.67	16	4.46	6	0.84	24	0.23
2/26/2024	11	439,000	665.15	439,000	665.15	17	4.64	5	0.77	25	0.23
2/27/2024	5	184,000	613.33	184,000	613.33	8	5.21	2	0.76	11	0.24
2/28/2024	8	326,000	679.17	326,000	679.17	13	4.78	5	0.88	19	0.24
2/29/2024	10	434,000	723.33	434,000	723.33	17	4.70	6	0.84	25	0.23
TOTALS											
MONTH	238	10731000	751.47	10731000	751.47	411	4.59	136	0.92	537	0.20
YEAR	466	21,672,000	775.11	21,672,000	775.11	833	4.61	276	0.92	1,072	0.20

**City of Sycamore
Distribution Chlorine Residuals
Facility #0370550**



	Area #1		Area #2		Area # 3		Tower #1		
Date	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Comments
2/1/2024	1.10	1.03	1.06	0.90	1.2	1.07	0.79	0.71	Well 8 10
2/2/2024	1.02	0.90	1.14	0.98	1.34	1.18	0.85	0.73	Well 9
2/3/2024							1.1	0.96	wells off
2/4/2024							0.99	0.91	wells 9 10
2/5/2024	1.32	1.12	0.9	0.78	1.43	1.24	0.91	0.82	Wells 6 8 10
2/6/2024	0.96	0.81	1.08	0.90	1.22	1.1	1.14	0.96	Wells off
2/7/2024	1.08	0.94	1.01	0.88	1.14	0.99	0.97	0.83	Well 9
2/8/2024	1.03	0.95	1.21	1.08	1.47	1.3	1.3	0.99	Well 6 9
2/9/2024	1.03	0.86	1.26	1.05	1.29	1.09	1.05	0.88	Well 6 9
2/10/2024							1.22	1.02	off
2/11/2024							1.08	0.90	off
2/12/2024	1.11	0.94	1.06	0.88	1.33	1.09	1.01	0.85	Well 8 10
2/13/2024	0.97	0.89	0.9	0.83	1.36	1.18	1.15	0.99	Well 6 8 9 10
2/14/2024	0.99	0.88	0.96	0.82	1.5	1.18	1.12	0.88	Well 8 10
2/15/2024	0.94	0.88	1.38	1.21	1.2	1.03	0.97	0.88	
2/16/2024	1.01	0.86	1.12	0.98	0.86	0.72	0.99	0.87	Wells 8 10
2/17/2024							0.94	0.86	
2/18/2024							0.96	0.89	
2/19/2024	0.94	0.86	0.92	0.86	0.88	0.79	0.98	0.90	
2/20/2024	0.88	0.82	0.98	0.92	0.88	0.8	0.95	0.87	
2/21/2024	1.15	0.97	1.1	0.98	0.98	0.9	1.1	0.97	
2/22/2024	1.10	0.95	1.03	0.91	1.25	1.1	0.94	0.88	
2/23/2024	0.93	0.84	1	0.89	1.09	0.96	0.9	0.83	
2/24/2024							0.96	0.80	
2/25/2024							1.01	0.82	
2/26/2024	1.03	0.89	1.17	1.00	0.99	0.9	1.02	0.86	
2/27/2024	0.77	0.67	0.91	0.80	0.78	0.63	0.98	0.88	
2/28/2024	0.91	0.77	0.89	0.80	1.16	0.97	0.87	0.77	
2/29/2024	0.86	0.70	0.96	0.81	0.99	0.78	1.32	1.14	

WELL 6

Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
2/1/2024	2.1	0.80	0.37	
2/2/2024	2.2	1.00	0.40	
2/3/2024	2.3	0.80	0.63	
2/4/2024	2.2	0.90	0.45	
2/5/2024	5.1	0.90	0.27	
2/6/2024	2.6	0.80	0.26	
2/7/2024	4.6	0.80	0.27	
2/8/2024	4.8	0.80	0.19	
2/9/2024	3.2	0.90	0.40	
2/10/2024	3.0	0.90	0.53	
2/11/2024	3.5	0.80	0.30	
2/12/2024	2.8	0.90	0.52	
2/13/2024	4.7	0.90	0.39	
2/14/2024	4.4	0.90	0.27	
2/15/2024	2.5	0.90	0.40	
2/16/2024	3.0	0.80	0.50	
2/17/2024	4.6	0.90	0.21	
2/18/2024	2.4	0.90	0.37	
2/19/2024	2.3	0.90	0.49	
2/20/2024	2.4	0.90	0.44	
2/21/2024	4.2	0.70	0.33	
2/22/2024	4.6	1.00	0.42	
2/23/2024	4.0	0.90	0.38	
2/24/2024	3.9	0.80	0.21	
2/25/2024	3.3	0.90	0.21	
2/26/2024	2.2	0.90	0.63	
2/27/2024	3.3	0.90	0.44	
2/28/2024	3.9	1.00	0.46	
2/29/2024	2.9	0.80	0.50	

WELL 7
Water Quality Control

[illegible]

WELL 8 **Water Quality Control**

Date	Total Chlorine	Fluoride	Phosphate	Initials	Comments
2/1/2024	4.7	0.70	0.46		
2/2/2024	3.8	1.00	0.44		tube
2/3/2024	3.7	0.80	0.41		tube
2/4/2024	3.6	0.70	0.59		tube
2/5/2024	4.4	0.80	0.57		
2/6/2024	3.8	0.80	0.42		tube
2/7/2024	4.0	0.80	0.52		tube
2/8/2024	3.9	0.80	0.46		tube
2/9/2024	4.1	0.70	0.49		tube
2/10/2024	4.5	0.70	0.46		
2/11/2024	5.0	0.70	0.41		
2/12/2024	4.8	0.70	0.38		
2/13/2024	4.9	0.80	0.53		
2/14/2024	4.1	0.80	0.42		
2/15/2024	4.4	0.80	0.37		
2/16/2024	5.2	0.70	0.30		
2/17/2024	4.0	0.70	0.43		tube
2/18/2024	3.8	0.70	0.38		tube
2/19/2024	3.4	0.70	0.35		tube
2/20/2024	3.2	0.80	0.41		tube
2/21/2024	4.8	0.80	0.29		
2/22/2024	3.4	1.00	0.58		tube
2/23/2024	2.8	0.70	0.46		tube
2/24/2024	3.1	0.70	0.44		tube
2/25/2024	3.6	0.80	0.49		tube
2/26/2024	4.9	0.70	0.23		
2/27/2024	3.6	0.80	0.63		tube
2/28/2024	4.8	0.80	0.19		
2/29/2024	3.9	0.70	0.38		tube

WELL 9
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials	Comments
2/1/2024	4.8	0.80	0.33		tube
2/2/2024	4.4	0.80	0.21		
2/3/2024	3.1	0.70	0.59		tube
2/4/2024	4.5	0.80	0.30		
2/5/2024	4.7	0.90	0.47		tube
2/6/2024	4.8	0.90	0.36		tube
2/7/2024	4.7	1.00	0.32		
2/8/2024	5.1	0.90	0.23		
2/9/2024	4.7	0.80	0.52		tube
2/10/2024	4.7	0.90	0.52		tube
2/11/2024	4.5	0.80	0.38		tube
2/12/2024	5.1	0.80	0.38		
2/13/2024	5.2	0.90	0.44		
2/14/2024	4.1	0.90	0.42		tube
2/15/2024	4.6	0.80	0.18		
2/16/2024	4.8	0.90	0.49		tube
2/17/2024	4.2	0.80	0.37		tube
2/18/2024	4.0	0.90	0.47		tube
2/19/2024	3.9	0.90	0.36		tube
2/20/2024	4.6	0.90	0.33		tube
2/21/2024	4.2	0.80	0.40		
2/22/2024	5.2	0.90	0.32		
2/23/2024	4.0	0.90	0.59		tube
2/24/2024	4.3	0.90	0.26		
2/25/2024	3.4	0.90	0.58		tube
2/26/2024	4.8	1.00	0.22		tube
2/27/2024	5.3	0.70	0.48		tube
2/28/2024	4.4	0.80	0.41		tube
2/29/2024	4.9	0.80	0.27		

WELL 10
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials	Comments
2/1/2024	4.0	1.00	0.20		running
2/2/2024	1.2	1.00	0.49		tube
2/3/2024	1.9	1.00	0.36		tube
2/4/2024	4.3	0.90	0.27		running
2/5/2024	4.2	0.90	0.44		tube
2/6/2024	1.4	1.00	0.50		tube
2/7/2024	4.1	1.00	0.36		tube
2/8/2024	1.4	1.00	0.39		tube
2/9/2024	1.4	0.80	0.38		tube
2/10/2024	2.8	0.90	0.25		tube
2/11/2024	4.4	1.00	0.39		
2/12/2024	4.9	0.90	0.31		
2/13/2024	4.5	0.90	0.39		
2/14/2024	4.8	0.90	0.13		
2/15/2024	2.2	1.00	0.29		tube
2/16/2024	4.5	0.90	0.28		
2/17/2024	2.4	1.00	0.24		tube
2/18/2024	2.8	0.90	0.27		tube
2/19/2024	3.1	0.90	0.27		tube
2/20/2024	2.4	0.80	0.30		tube
2/21/2024	3.8	0.90	0.29		
2/22/2024	4.3	0.90	0.38		
2/23/2024	4.2	1.00	0.33		
2/24/2024	1.8	1.00	0.51		tube
2/25/2024	4.0	0.90	0.73		
2/26/2024	2.0	0.70	0.26		tube
2/27/2024	5.0	0.90	0.29		
2/28/2024	5.0	1.00	0.18		
2/29/2024	4.8	1.00	0.21		