



PUBLIC WORKS
Water Division

IEPA - Rockford Regional Office
4302 N. Main St
Rockford, IL 61103

February 5, 2025

Re: Monthly Operating Reports: City of Sycamore – IL0370550

Please find the enclosed operating reports for the City of Sycamore, IL.

- Monthly Operating Reports
- Water Quality Control
- Monthly Chlorine Distribution

Should you have any questions or concerns, please contact me at (815) 895-3545 or by email at maanderson@cityofsycamore.com

Sincerely Yours,

Matt Anderson
City of Sycamore
Director of Public Works

City of Sycamore

Water Division

Monthly Operations Report

2025

DATE	HOURS RUN	PUMPAGE (WELL)	PUMPAGE (WRT)	WELL (gpm)	WRT (gpm)	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	24	1,440,000	1,472,000	1,000.00	1,022.22	58	4.83	14	0.81	58	0.16
1/2/2025	29	1,548,000	1,557,000	889.66	894.83	71	5.50	15	0.81	64	0.17
1/3/2025	25	1,464,000	1,519,000	976.00	1,012.67	66	5.41	16	0.84	59	0.16
1/4/2025	22	1,203,000	1,229,000	911.36	931.06	56	5.58	13	0.84	52	0.18
1/5/2025	20	1,208,000	1,201,000	1,006.67	1,000.83	42	4.17	13	0.84	47	0.16
1/6/2025	35	1,914,000	1,941,000	911.43	924.29	87	5.45	22	0.86	78	0.17
1/7/2025	28	1,630,000	1,648,000	970.24	980.95	71	5.22	18	0.84	68	0.17
1/8/2025	31	1,757,000	1,793,000	944.62	963.98	74	5.05	20	0.85	72	0.17
1/9/2025	28	1,639,000	1,662,000	975.60	989.29	65	4.76	17	0.83	67	0.17
1/10/2025	25	1,340,000	1,379,000	893.33	919.33	57	5.10	14	0.83	56	0.17
1/11/2025	24	1,228,000	1,284,000	852.78	891.67	48	4.69	13	0.83	51	0.17
1/12/2025	27	1,484,000	1,501,000	916.05	926.54	63	5.09	14	0.80	64	0.18
1/13/2025	35	1,781,000	1,841,000	848.10	876.67	74	4.98	20	0.85	77	0.18
1/14/2025	22	1,196,000	1,234,000	906.06	934.85	52	5.21	12	0.82	54	0.18
1/15/2025	33	1,801,000	1,841,000	909.60	929.80	82	5.46	20	0.85	87	0.20
1/16/2025	25	1,373,000	1,419,000	915.33	946.00	55	4.80	16	0.86	56	0.17
1/17/2025	31	1,730,000	1,764,000	930.11	948.39	71	4.92	17	0.81	72	0.17
1/18/2025	25	1,377,000	1,396,000	918.00	930.67	52	4.53	12	0.78	56	0.17
1/19/2025	21	1,276,000	1,299,000	1,012.70	1,030.95	49	4.60	14	0.84	50	0.16
1/20/2025	28	1,503,000	1,501,000	894.64	893.45	56	4.47	14	0.80	66	0.18
1/21/2025	32	1,759,000	1,820,000	916.15	947.92	71	4.84	21	0.87	74	0.17
1/22/2025	30	1,501,000	1,527,000	833.89	848.33	62	4.95	16	0.83	63	0.17
1/23/2025	24	1,319,000	1,376,000	915.97	955.56	58	5.27	14	0.83	58	0.18
1/24/2025	34	1,909,000	1,945,000	935.78	953.43	74	4.65	20	0.83	80	0.17
1/25/2025	22	1,164,000	1,203,000	881.82	911.36	49	5.05	12	0.82	50	0.18
1/26/2025	36	1,998,000	2,030,000	925.00	939.81	77	4.62	19	0.80	82	0.17
1/27/2025	32	1,696,000	1,745,000	883.33	908.85	68	4.81	17	0.82	76	0.18
1/28/2025	31	1,746,000	1,782,000	938.71	958.06	67	4.60	19	0.84	71	0.17
1/29/2025	35	1,892,000	1,939,000	900.95	923.33	76	4.82	22	0.86	79	0.17
1/30/2025	32	1,765,000	1,799,000	919.27	936.98	70	4.76	18	0.82	77	0.18
1/31/2025	29	1,537,000	1,566,000	883.33	900.00	61	4.76	16	0.83	69	0.18
TOTALS											
MONTH	875.0	48,178,000	49,213,000	917.68	937.39	1,982	4.93	508	0.83	2,033	0.17
YEAR	875.0	48,178,000	49,213,000	917.68	937.39	1,982	4.93	508	0.83	2,033	0.17

Matt Anderson
Water Division

City of Sycamore - Facility #0370550

WELL 6

DATE	HOURS RUN	WELL6 RAW	WELL 6 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/2/2025	15	785,000	872.22	771,000	856.67	38	5.80	6	0.68	34	0.18
1/3/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/4/2025	8	426,000	887.50	419,000	872.92	20	5.63	2	0.60	19	0.18
1/5/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/6/2025	10	523,000	871.67	513,000	855.00	25	5.73	9	0.95	22	0.17
1/7/2025	7	375,000	892.86	369,000	878.57	18	5.76	4	0.77	16	0.17
1/8/2025	5	269,000	896.67	265,000	883.33	12	5.35	2	0.68	12	0.18
1/9/2025	3	182,000	1,011.11	178,000	988.89	8	5.27	1	0.62	8	0.18
1/10/2025	6	299,000	830.56	294,000	816.67	13	5.21	2	0.66	13	0.18
1/11/2025	3	158,000	877.78	155,000	861.11	6	4.55	1	0.65	6	0.15
1/12/2025	13	703,000	901.28	690,000	884.62	32	5.46	5	0.67	31	0.18
1/13/2025	8	429,000	893.75	422,000	879.17	20	5.59	3	0.67	19	0.18
1/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/15/2025	4	215,000	895.83	211,000	879.17	9	5.02	1	0.60	9	0.17
1/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/17/2025	10	557,000	928.33	547,000	911.67	20	4.31	4	0.67	25	0.18
1/18/2025	8	429,000	893.75	421,000	877.08	15	4.19	2	0.60	18	0.17
1/19/2025	4	202,000	841.67	199,000	829.17	7	4.16	2	0.75	9	0.18
1/20/2025	7	403,000	959.52	396,000	942.86	14	4.17	2	0.61	18	0.18
1/21/2025	10	501,000	835.00	492,000	820.00	18	4.31	3	0.64	22	0.18
1/22/2025	5	258,000	860.00	256,000	853.33	10	4.65	2	0.69	10	0.16
1/23/2025	8	419,000	872.92	409,000	852.08	15	4.29	4	0.74	18	0.18
1/24/2025	3	168,000	933.33	166,000	922.22	6	4.28	1	0.64	8	0.19
1/25/2025	10	513,000	855.00	504,000	840.00	20	4.67	4	0.69	21	0.17
1/26/2025	3	185,000	1,027.78	181,000	1,005.56	7	4.54	1	0.62	8	0.18
1/27/2025	9	471,000	872.22	463,000	857.41	17	4.33	4	0.71	22	0.19
1/28/2025	5	278,000	926.67	273,000	910.00	10	4.31	2	0.67	11	0.16
1/29/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/30/2025	9	471,000	872.22	464,000	859.26	16	4.07	3	0.65	21	0.18
1/31/2025	7	398,000	947.62	390,000	928.57	15	4.52	3	0.68	18	0.18
TOTALS											
MONTH	180	9,617,000	890.46	9,448,000	874.81	391	4.96	73	0.80	418	0.18
YEAR	180	9,617,000	890.46	9,448,000	874.81	391	4.96	73	0.80	418	0.18

City of Sycamore - Facility #0370550

WELL 7

DATE	HOURS RUN	WELL 7 RAW	WELL 7 GPM	Finished PUMPED	Finished GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/2/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/3/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/4/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/5/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/6/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/7/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/8/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/9/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/10/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/12/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/13/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/15/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/17/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/18/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/19/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/20/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/22/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/23/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/24/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/25/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/26/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/27/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/28/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/29/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/30/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/31/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
TOTALS											
MONTH	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
YEAR	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!

**City of Sycamore - Facility #0370550
WELL 8**

DATE	HOURS RUN	WELL 8 RAW	WELL 8 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	8	512,000	1,066.67	506,000	1,054.17	19	4.45	5	0.77	21	0.17
1/2/2025	4	257,000	1,070.83	255,000	1,062.50	10	4.67	3	0.82	10	0.16
1/3/2025	5	357,000	1,190.00	352,000	1,173.33	13	4.37	3	0.74	16	0.18
1/4/2025	6	370,000	1,027.78	366,000	1,016.67	16	5.19	5	0.88	15	0.17
1/5/2025	9	530,000	981.48	523,000	968.52	19	4.30	6	0.82	21	0.16
1/6/2025	7	452,000	1,076.19	447,000	1,064.29	18	4.77	4	0.75	18	0.16
1/7/2025	7	479,000	1,140.48	473,000	1,126.19	19	4.76	5	0.79	20	0.17
1/8/2025	10	638,000	1,063.33	631,000	1,051.67	22	4.13	7	0.81	25	0.16
1/9/2025	9	560,000	1,037.04	553,000	1,024.07	20	4.28	6	0.80	23	0.17
1/10/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/12/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/13/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/14/2025	6	376,000	1,044.44	369,000	1,025.00	15	4.78	4	0.80	20	0.22
1/15/2025	12	724,000	1,005.56	707,000	981.94	31	5.13	8	0.81	40	0.23
1/16/2025	10	642,000	1,070.00	653,000	1,088.33	25	4.67	8	0.84	24	0.15
1/17/2025	5	309,000	1,030.00	315,000	1,050.00	12	4.66	3	0.76	12	0.16
1/18/2025	8	533,000	1,110.42	541,000	1,127.08	20	4.50	5	0.75	20	0.15
1/19/2025	11	701,000	1,062.12	712,000	1,078.79	25	4.28	8	0.81	25	0.15
1/20/2025	4	297,000	1,237.50	302,000	1,258.33	11	4.44	2	0.68	11	0.15
1/21/2025	9	596,000	1,103.70	606,000	1,122.22	22	4.43	7	0.82	21	0.14
1/22/2025	8	470,000	979.17	477,000	993.75	19	4.85	6	0.85	17	0.15
1/23/2025	3	186,000	1,033.33	189,000	1,050.00	7	4.51	2	0.79	8	0.18
1/24/2025	13	853,000	1,093.59	867,000	1,111.54	32	4.50	9	0.79	31	0.15
1/25/2025	2	121,000	1,008.33	122,000	1,016.67	5	4.95	1	0.73	5	0.17
1/26/2025	13	870,000	1,115.38	884,000	1,133.33	32	4.41	10	0.81	31	0.15
1/27/2025	4	240,000	1,000.00	244,000	1,016.67	9	4.50	2	0.73	9	0.15
1/28/2025	11	764,000	1,157.58	775,000	1,174.24	27	4.24	9	0.82	28	0.15
1/29/2025	13	847,000	1,085.90	860,000	1,102.56	34	4.81	9	0.79	31	0.15
1/30/2025	10	636,000	1,060.00	646,000	1,076.67	25	4.71	6	0.76	23	0.15
1/31/2025	8	486,000	1,012.50	493,000	1,027.08	19	4.69	5	0.78	20	0.17
TOTALS											
MONTH	215	13,806,000	1,070.23	13,868,000	1,075.04	526	4.55	148	0.87	545	0.16
YEAR	215	13,806,000	1,070.23	13,868,000	1,075.04	526	4.55	148	0.87	545	0.16

**City of Sycamore - Facility #0370550
WELL 9**

DATE	HOURS RUN	WELL 9 RAW	WELL 9 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	8	420,000	875.00	458,000	954.17	20	5.71	5	0.72	19	0.18
1/2/2025	6	284,000	788.89	309,000	858.33	14	5.91	4	0.78	12	0.17
1/3/2025	12	672,000	933.33	732,000	1,016.67	37	6.60	9	0.76	27	0.16
1/4/2025	8	407,000	847.92	444,000	925.00	20	5.89	6	0.79	18	0.18
1/5/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/6/2025	10	494,000	823.33	536,000	893.33	28	6.80	6	0.73	21	0.17
1/7/2025	6	316,000	877.78	346,000	961.11	17	6.45	4	0.74	14	0.18
1/8/2025	10	529,000	881.67	576,000	960.00	28	6.35	7	0.76	22	0.17
1/9/2025	7	388,000	923.81	422,000	1,004.76	19	5.87	5	0.75	16	0.17
1/10/2025	9	482,000	892.59	526,000	974.07	23	5.72	7	0.79	21	0.18
1/11/2025	13	665,000	852.56	724,000	928.21	28	5.05	8	0.72	28	0.17
1/12/2025	6	346,000	961.11	376,000	1,044.44	15	5.20	5	0.79	15	0.18
1/13/2025	15	747,000	830.00	814,000	904.44	33	5.30	10	0.76	31	0.17
1/14/2025	9	500,000	925.93	545,000	1,009.26	25	6.00	5	0.67	20	0.16
1/15/2025	13	676,000	866.67	737,000	944.87	35	6.21	9	0.76	29	0.17
1/16/2025	5	241,000	803.33	276,000	920.00	10	4.98	3	0.72	11	0.19
1/17/2025	11	588,000	890.91	626,000	948.48	28	5.71	7	0.73	23	0.16
1/18/2025	4	196,000	816.67	215,000	895.83	9	5.51	3	0.80	8	0.17
1/19/2025	3	178,000	988.89	193,000	1,072.22	9	6.06	2	0.71	8	0.18
1/20/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/21/2025	13	662,000	848.72	722,000	925.64	31	5.61	11	0.84	31	0.19
1/22/2025	5	243,000	810.00	264,000	880.00	12	5.92	2	0.63	11	0.18
1/23/2025	13	714,000	915.38	778,000	997.44	36	6.05	8	0.70	32	0.18
1/24/2025	5	268,000	893.33	292,000	973.33	13	5.82	4	0.80	13	0.20
1/25/2025	10	530,000	883.33	577,000	961.67	24	5.43	7	0.75	24	0.18
1/26/2025	5	250,000	833.33	272,000	906.67	12	5.76	3	0.72	11	0.18
1/27/2025	11	599,000	907.58	652,000	987.88	27	5.40	7	0.72	27	0.18
1/28/2025	7	322,000	766.67	352,000	838.10	15	5.59	4	0.73	15	0.19
1/29/2025	7	382,000	909.52	416,000	990.48	17	5.34	5	0.75	17	0.18
1/30/2025	6	346,000	961.11	377,000	1,047.22	16	5.54	5	0.79	17	0.20
1/31/2025	7	337,000	802.38	367,000	873.81	15	5.34	4	0.72	16	0.19
TOTALS											
MONTH	244	12,782,000	873.09	13,924,000	951.09	616	5.30	165	0.69	557	0.16
YEAR	244	12,782,000	873.09	13,924,000	951.09	616	5.30	165	0.69	557	0.16

**City of Sycamore - Facility #0370550
WELL 10**

DATE	HOURS RUN	WELL 10 RAW	WELL 10 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
1/1/2025	8	508,000	1,058.33	508,000	1,058.33	19	4.48	4	0.68	18	0.14
1/2/2025	4	222,000	925.00	222,000	925.00	9	4.86	2	0.71	8	0.15
1/3/2025	8	435,000	906.25	435,000	906.25	16	4.41	4	0.71	16	0.15
1/4/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/5/2025	11	678,000	1,027.27	678,000	1,027.27	23	4.07	7	0.74	26	0.16
1/6/2025	8	445,000	927.08	445,000	927.08	16	4.31	3	0.65	17	0.16
1/7/2025	8	460,000	958.33	460,000	958.33	17	4.43	5	0.76	18	0.16
1/8/2025	6	321,000	891.67	321,000	891.67	12	4.48	4	0.80	13	0.17
1/9/2025	9	509,000	942.59	509,000	942.59	18	4.24	5	0.73	20	0.16
1/10/2025	10	559,000	931.67	559,000	931.67	21	4.50	5	0.71	22	0.16
1/11/2025	8	405,000	843.75	405,000	843.75	14	4.14	4	0.73	17	0.17
1/12/2025	8	435,000	906.25	435,000	906.25	16	4.41	4	0.71	18	0.17
1/13/2025	12	605,000	840.28	605,000	840.28	21	4.16	7	0.78	27	0.18
1/14/2025	7	320,000	761.90	320,000	761.90	12	4.50	3	0.72	14	0.18
1/15/2025	4	186,000	775.00	186,000	775.00	7	4.51	2	0.76	9	0.20
1/16/2025	10	490,000	816.67	490,000	816.67	20	4.89	5	0.74	21	0.17
1/17/2025	5	276,000	920.00	276,000	920.00	11	4.78	3	0.76	12	0.18
1/18/2025	5	219,000	730.00	219,000	730.00	8	4.38	2	0.71	10	0.19
1/19/2025	3	195,000	1,083.33	195,000	1,083.33	8	4.92	2	0.74	8	0.17
1/20/2025	17	803,000	787.25	803,000	787.25	31	4.63	10	0.80	37	0.19
1/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/22/2025	12	530,000	736.11	530,000	736.11	21	4.75	6	0.77	25	0.19
1/23/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/24/2025	13	620,000	794.87	620,000	794.87	23	4.45	6	0.73	28	0.18
1/25/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
1/26/2025	15	693,000	770.00	693,000	770.00	26	4.50	5	0.66	32	0.19
1/27/2025	8	386,000	804.17	386,000	804.17	15	4.66	4	0.75	18	0.19
1/28/2025	8	382,000	795.83	382,000	795.83	15	4.71	4	0.75	17	0.18
1/29/2025	15	663,000	736.67	663,000	736.67	25	4.52	8	0.79	31	0.19
1/30/2025	7	312,000	742.86	312,000	742.86	13	5.00	4	0.81	16	0.21
1/31/2025	7	316,000	752.38	316,000	752.38	12	4.55	4	0.81	15	0.19
TOTALS											
MONTH	236	11,973,000	845.55	11,973,000	845.55	449	4.50	122	0.86	513	0.17
YEAR	236	11,973,000	845.55	11,973,000	845.55	449	4.50	122	0.86	513	0.17

City of Sycamore
Distribution Chlorine Residuals
Facility #0370550



	Area #1		Area #2		Area # 3		Tower #1		
Date	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Comments
1/1/2025	0.92	0.84	1.04	0.90	0.96	0.82	1.03	0.88	
1/2/2025	0.91	0.75	1.09	0.95	1.9	1.76	1.04	0.82	
1/3/2025	0.99	0.78	1	0.90	1.2	0.96	0.78	0.66	
1/4/2025							1.2	1.03	
1/5/2025							0.9	0.74	
1/6/2025	1.12	1.04	1.18	1.10	1.09	0.99	1.24	1.16	
1/7/2025	0.99	0.82	1.23	1.10	1.2	1.08	1.02	0.86	
1/8/2025	1.19	1.04	1.26	0.97	1.32	1.05	1.25	1.05	
1/9/2025	1.26	1.06	1.35	1.10	1.95	1.8	1.09	1.01	
1/10/2025	0.76	0.64	0.98	0.91	1.86	1.68	1.09	0.92	
1/11/2025							1.01	0.90	
1/12/2025							0.78	0.66	
1/13/2025	1.47	1.31	1.23	1.00	1.71	1.58	0.61	0.51	
1/14/2025	1.31	1.15	1.28	0.99	2.1	1.9	0.95	0.74	
1/15/2025	1.16	1.03	0.96	0.88	1.02	0.89	1.53	1.30	
1/16/2025	1.04	0.95	1.14	0.96	1.22	1.18	1.22	0.89	
1/17/2025	0.87	0.77	1.03	0.92	1.08	0.88	1.01	0.80	
1/18/2025							1.03	0.78	
1/19/2025							1.02	0.79	
1/20/2025	1.02	0.88	0.95	0.82	1	0.9	0.96	0.76	
1/21/2025	0.63	0.56	0.95	0.78	0.65	0.55	0.9	0.75	
1/22/2025	1.36	1.29	1.19	0.90	1.26	1.16	0.95	0.75	
1/23/2025	0.66	0.53	0.88	0.80	1.08	0.93	0.91	0.76	
1/24/2025	0.72	0.61	1.17	1.07	1.2	1.12	0.64	0.55	
1/25/2025							0.8	0.62	
1/26/2025							1.05	0.83	
1/27/2025	0.96	0.81	1.37	1.22	0.78	0.66	0.76	0.60	
1/28/2025	0.97	0.88	1.09	0.88	1.04	0.85	0.85	0.65	
1/29/2025	0.71	0.59	1.33	1.18	1.15	1.05	0.83	0.74	
1/30/2025	0.88	0.74	1.34	1.13	1.07	0.95	0.8	0.64	
1/31/2025	1.02	0.90	1.04	0.89	1.15	0.92	1.01	0.84	

WELL 6
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
1/1/2025	1.5	0.80	0.61	
1/2/2025	4.7	0.80	0.50	
1/3/2025	1.6	0.80	0.70	
1/4/2025	4.4	0.80	0.45	
1/5/2025	5.0	0.80	0.23	
1/6/2025	4.8	0.70	0.21	
1/7/2025	5.8	0.80	0.34	
1/8/2025	3.6	0.80	0.66	
1/9/2025	3.0	0.70	0.43	
1/10/2025	5.1	0.80	0.35	
1/11/2025	3.6	0.80	0.48	
1/12/2025	5.2	0.80	0.24	
1/13/2025	4.6	0.70	0.20	
1/14/2025	5.1	0.80	0.27	
1/15/2025	2.4	0.80	0.25	
1/16/2025	2.0	0.80	0.73	
1/17/2025	1.7	1.00	0.46	
1/18/2025	1.8	0.80	0.22	
1/19/2025	1.9	0.80	0.37	
1/20/2025	1.7	0.80	0.37	
1/21/2025	1.1	0.70	0.50	
1/22/2025	5.0	0.80	0.31	
1/23/2025	1.7	0.90	0.51	
1/24/2025	4.4	0.80	0.39	
1/25/2025	1.5	0.80	0.46	
1/26/2025	1.4	0.80	0.48	
1/27/2025	1.5	0.90	0.43	
1/28/2025	1.4	0.80	0.48	
1/29/2025	4.2	0.80	0.23	
1/30/2025	5.0	0.90	0.44	
1/31/2025	4.9	0.80	0.22	

WELL 7

Water Quality Control

[illegible]

WELL 8

Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
1/1/2025	3.1	0.70	0.42	
1/2/2025	2.8	0.80	0.40	
1/3/2025	3.4	0.80	0.32	
1/4/2025	4.6	0.70	0.27	
1/5/2025	4.2	0.80	0.32	
1/6/2025	3.1	0.70	0.46	
1/7/2025	3.8	0.80	0.49	
1/8/2025	4.3	0.70	0.32	
1/9/2025	4.6	0.70	0.21	
1/10/2025	5.1	0.70	0.35	
1/11/2025	2.7	0.80	0.51	
1/12/2025	2.5	0.80	0.59	
1/13/2025	2.7	0.90	0.62	
1/14/2025	4.0	0.80	0.13	
1/15/2025	4.3	0.70	0.47	
1/16/2025	5.4	0.80	0.31	
1/17/2025	3.7	1.00	0.51	
1/18/2025	3.6	0.70	0.29	
1/19/2025	3.7	0.70	0.20	
1/20/2025	2.9	0.70	0.45	
1/21/2025	5.1	0.70	0.12	
1/22/2025	5.1	0.70	0.30	
1/23/2025	5.1	0.70	0.38	
1/24/2025	3.2	0.70	0.43	
1/25/2025	4.7	0.70	0.21	
1/26/2025	4.7	0.80	0.29	
1/27/2025	5.2	0.70	0.23	
1/28/2025	4.6	0.70	0.18	
1/29/2025	4.4	0.70	0.31	
1/30/2025	4.1	0.90	0.27	
1/31/2025	5.2	0.80	0.31	

WELL 9
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
1/1/2025	5.4	0.80	0.21	
1/2/2025	5.2	0.80	0.16	
1/3/2025	5.1	0.80	0.11	
1/4/2025	5.1	0.80	0.40	
1/5/2025	4.9	0.70	0.67	
1/6/2025	5.0	0.80	0.28	
1/7/2025	5.7	0.90	0.19	
1/8/2025	5.1	0.80	0.21	
1/9/2025	5.4	0.80	0.59	
1/10/2025	5.4	0.80	0.22	
1/11/2025	4.9	0.80	0.41	
1/12/2025	4.0	0.80	0.29	
1/13/2025	5.3	0.70	0.31	
1/14/2025	5.2	0.80	0.28	
1/15/2025	5.6	0.90	0.39	
1/16/2025	4.1	0.80	0.48	
1/17/2025	5.5	0.80	0.20	
1/18/2025	3.2	0.70	0.37	
1/19/2025	2.3	0.80	0.37	
1/20/2025	2.4	0.80	0.50	
1/21/2025	4.5	0.90	0.38	
1/22/2025	4.9	0.90	0.46	
1/23/2025	5.1	0.90	0.38	
1/24/2025	5.1	0.80	0.14	
1/25/2025	3.8	0.90	0.39	
1/26/2025	4.9	0.90	0.47	
1/27/2025	3.1	0.90	0.48	
1/28/2025	4.1	0.80	0.46	
1/29/2025	4.0	0.80	0.24	
1/30/2025	5.6	0.90	0.32	
1/31/2025	5.7	0.90	0.38	

WELL 10
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
1/1/2025	1.2	0.80	0.44	
1/2/2025	4.0	0.80	0.10	
1/3/2025	1.2	0.80	0.61	
1/4/2025	1.1	0.80	0.53	
1/5/2025	2.3	0.80	0.39	
1/6/2025	2.4	0.90	0.41	
1/7/2025	1.3	0.90	0.42	
1/8/2025	4.5	0.70	0.11	
1/9/2025	4.4	0.70	0.50	
1/10/2025	4.8	0.70	0.40	
1/11/2025	2.6	0.80	0.32	
1/12/2025	4.3	0.80	0.45	
1/13/2025	3.5	0.80	0.22	
1/14/2025	1.4	0.90	0.42	
1/15/2025	4.2	0.90	0.40	
1/16/2025	1.1	0.80	0.48	
1/17/2025	1.2	1.00	0.52	
1/18/2025	1.6	0.90	0.73	
1/19/2025	1.5	0.80	0.61	
1/20/2025	1.4	0.80	0.85	
1/21/2025	4.8	0.90	0.12	
1/22/2025	4.8	0.90	0.28	
1/23/2025	4.7	0.80	0.16	
1/24/2025	1.3	0.90	0.61	
1/25/2025	4.8	0.80	0.33	
1/26/2025	4.2	0.80	0.27	
1/27/2025	5.2	0.90	0.26	
1/28/2025	4.7	0.80	0.22	
1/29/2025	1.2	0.90	0.53	
1/30/2025	1.4	0.80	0.54	
1/31/2025	1.3	0.90	0.55	