



PUBLIC WORKS
Water Division

IEPA - Rockford Regional Office
4302 N. Main St
Rockford, IL 61103

January 5, 2026

Re: Monthly Operating Reports: City of Sycamore – IL0370550

Please find the enclosed operating reports for the City of Sycamore, IL.

- Monthly Operating Reports
- Water Quality Control
- Monthly Chlorine Distribution

Should you have any questions or concerns, please contact me at (815) 895-3545 or by email at maanderson@cityofsycamore.com

Sincerely Yours,

Matt Anderson
City of Sycamore
Director of Public Works

City of Sycamore

Water Division

Monthly Operations Report

2025

DATE	HOURS RUN	PUMPAGE (WELL)	PUMPAGE (FINISHED)	WELL (gpm)	WRT (gpm)	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
12/1/2025	24	1,381,000	1,427,000	959.03	990.97	58	5.04	14	0.82	66	0.19
12/2/2025	27	1,677,000	1,724,000	1,035.19	1,064.20	78	5.58	14	0.77	83	0.20
12/3/2025	28	1,655,000	1,657,000	985.12	986.31	54	3.91	16	0.81	78	0.19
12/4/2025	26	1,592,000	1,638,000	1,020.51	1,050.00	65	4.90	14	0.78	78	0.20
12/5/2025	27	1,694,000	1,708,000	1,045.68	1,054.32	56	3.96	19	0.85	82	0.20
12/6/2025	25	1,470,000	1,515,000	980.00	1,010.00	54	4.40	13	0.78	70	0.19
12/7/2025	29	1,671,000	1,705,000	960.34	979.89	68	4.88	16	0.80	83	0.20
12/8/2025	27	1,620,000	1,633,000	1,000.00	1,008.02	67	4.96	14	0.78	81	0.20
12/9/2025	28	1,626,000	1,580,000	967.86	940.48	60	4.42	16	0.80	76	0.19
12/10/2025	28	1,705,000	1,752,000	1,014.88	1,042.86	65	4.57	18	0.83	85	0.20
12/11/2025	28	1,841,000	1,895,000	1,095.83	1,127.98	78	5.08	19	0.82	93	0.21
12/12/2025	26	1,511,000	1,547,000	968.59	991.67	69	5.48	13	0.78	73	0.20
12/13/2025	29	1,659,000	1,683,000	953.45	967.24	62	4.48	17	0.82	78	0.19
12/14/2025	26	1,615,000	1,705,000	1,035.26	1,092.95	82	6.09	15	0.80	84	0.21
12/15/2025	31	1,791,000	1,820,000	962.90	978.49	72	4.82	18	0.82	91	0.21
12/16/2025	27	1,653,000	1,715,000	1,020.37	1,058.64	70	5.08	18	0.84	81	0.20
12/17/2025	28	1,626,000	1,712,000	967.86	1,019.05	68	5.01	17	0.83	84	0.21
12/18/2025	34	2,085,000	2,105,000	1,022.06	1,031.86	83	4.77	19	0.79	103	0.20
12/19/2025	28	1,679,000	1,729,000	999.40	1,029.17	74	5.28	16	0.80	79	0.19
12/20/2025	28	1,580,000	1,596,000	940.48	950.00	58	4.40	35	1.15	75	0.19
12/21/2025	24	1,477,000	1,526,000	1,025.69	1,059.72	58	4.71	16	0.84	73	0.20
12/22/2025	30	1,664,000	1,666,000	924.44	925.56	64	4.61	15	0.79	82	0.20
12/23/2025	29	1,697,000	1,761,000	975.29	1,012.07	73	5.16	18	0.83	86	0.21
12/24/2025	28	1,583,000	1,620,000	942.26	964.29	61	4.62	15	0.80	79	0.20
12/25/2025	24	1,497,000	1,556,000	1,039.58	1,080.56	59	4.73	15	0.82	70	0.19
12/26/2025	20	1,075,000	1,107,000	895.83	922.50	42	4.68	11	0.82	55	0.21
12/27/2025	39	2,151,000	2,166,000	919.23	925.64	82	4.57	22	0.82	112	0.21
12/28/2025	21	1,268,000	1,293,000	1,006.35	1,026.19	50	4.73	13	0.82	65	0.21
12/29/2025	24	1,390,000	1,442,000	965.28	1,001.39	66	5.69	16	0.86	71	0.21
12/30/2025	27	1,607,000	1,668,000	991.98	1,029.63	71	5.30	14	0.78	88	0.22
12/31/2025	29	1,683,000	1,707,000	967.24	981.03	63	4.49	18	0.83	84	0.20
TOTALS											
MONTH	849.0	50,223,000	51,358,000	985.92	1,008.21	2,030	4.85	514	0.82	2,488	0.20
YEAR	11,302.0	658,222,000	663,622,000	970.66	978.62	26,198	4.77	6,362	0.81	29,773	0.18

City of Sycamore - Facility #0370550

WELL 6

DATE	HOURS RUN	WELL6 RAW	WELL 6 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
12/1/2025	7	351,000	835.71	345,000	821.43	11	3.76	4	0.79	16	0.19
12/2/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/3/2025	8	409,000	852.08	402,000	837.50	13	3.81	4	0.74	19	0.19
12/4/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/5/2025	6	334,000	927.78	328,000	911.11	10	3.59	4	0.81	16	0.20
12/6/2025	8	436,000	908.33	429,000	893.75	14	3.85	4	0.73	20	0.19
12/7/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/8/2025	7	369,000	878.57	363,000	864.29	12	3.90	4	0.77	18	0.20
12/9/2025	4	193,000	804.17	189,000	787.50	6	3.73	2	0.76	9	0.19
12/10/2025	6	315,000	875.00	310,000	861.11	10	3.81	4	0.83	15	0.19
12/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/12/2025	1	57,000	950.00	56,000	933.33	2	4.21	0	0.47	1	0.07
12/13/2025	11	606,000	918.18	596,000	903.03	19	3.76	6	0.75	28	0.19
12/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/15/2025	3	137,000	761.11	127,000	705.56	4	3.50	1	0.69	6	0.18
12/16/2025	6	329,000	913.89	331,000	919.44	11	4.01	4	0.80	16	0.20
12/17/2025	3	137,000	761.11	135,000	750.00	4	3.50	1	0.67	6	0.18
12/18/2025	2	153,000	1,275.00	148,000	1,233.33	5	3.92	1	0.66	6	0.16
12/19/2025	10	529,000	881.67	522,000	870.00	16	3.63	7	0.84	22	0.17
12/20/2025	9	443,000	820.37	436,000	807.41	15	4.06	4	0.72	21	0.19
12/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/22/2025	10	529,000	881.67	520,000	866.67	17	3.85	6	0.79	25	0.19
12/23/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/24/2025	10	533,000	888.33	524,000	873.33	18	4.05	6	0.79	25	0.19
12/25/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/26/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/27/2025	11	590,000	893.94	580,000	878.79	19	3.86	6	0.76	29	0.20
12/28/2025	8	432,000	900.00	425,000	885.42	14	3.89	5	0.79	21	0.20
12/29/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/30/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/31/2025	10	521,000	868.33	512,000	853.33	17	3.91	6	0.79	26	0.20
TOTALS											
MONTH	140	7,403,000	881.31	7,278,000	866.43	237	3.90	79	0.87	345	0.19
YEAR	3085	161,504,000	872.52	158,732,000	857.55	6,013	4.54	1,354	0.82	7,501	0.19

**City of Sycamore - Facility #0370550
WELL 7**

DATE	HOURS RUN	WELL 7 RAW	WELL 7 GPM	Finished PUMPED	Finished GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)	NaMnO4 Usage Gallons	MnSO4 Usage Gallons	Backwash (#)
12/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/2/2025	16	1,056,000	1,100.00	1,084,000	1,129.17	52	5.75	8	0.70	55	0.21	0	0	0
12/3/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/4/2025	10	605,000	1,008.33	622,000	1,036.67	29	5.59	4	0.68	32	0.21	0	0	0
12/5/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/6/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/7/2025	5	276,000	920.00	282,000	940.00	13	5.53	3	0.79	15	0.22	0	0	0
12/8/2025	11	708,000	1,072.73	727,000	1,101.52	33	5.44	5	0.69	38	0.21	0	0	0
12/9/2025	2	132,000	1,100.00	61,000	508.33	3	5.90	0.5	0.73	3	0.20	0	0	1
12/10/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/11/2025	7	468,000	1,114.29	481,000	1,145.24	22	5.48	4	0.73	24	0.20	0	0	0
12/12/2025	10	589,000	981.67	603,000	1,005.00	29	5.77	4	0.68	31	0.21	0	0	0
12/13/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/14/2025	13	814,000	1,043.59	836,000	1,071.79	42	6.02	6	0.70	42	0.20	0	0	0
12/15/2025	5	338,000	1,126.67	345,000	1,150.00	16	5.56	3	0.74	18	0.21	0	0	0
12/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/17/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/18/2025	12	752,000	1,044.44	772,000	1,072.22	35	5.44	6	0.71	40	0.21	0	0	0
12/19/2025	11	705,000	1,068.18	724,000	1,096.97	39	6.46	5	0.69	37	0.21	0	0	0
12/20/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/22/2025	8	484,000	1,008.33	495,000	1,031.25	24	5.81	3	0.67	26	0.21	0	0	0
12/23/2025	4	279,000	1,162.50	287,000	1,195.83	14	5.85	3	0.79	15	0.21	12	12	0
12/24/2025	8	483,000	1,006.25	495,000	1,031.25	23	5.57	3	0.67	25	0.21	0	0	0
12/25/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/26/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/27/2025	15	918,000	1,020.00	942,000	1,046.67	43	5.47	8	0.73	49	0.21	0	0	0
12/28/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/29/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
12/30/2025	15	962,000	1,068.89	988,000	1,097.78	44	5.34	7	0.70	52	0.21	0	0	0
12/31/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
TOTALS														
MONTH	152	9,569,000	1,049.23	9,744,000	1,068.42	461	5.67	72.5	0.80	502	0.21	12	12	1
YEAR	1473	91,739,000	1,038.01	93,281,000	1,055.45	4,271	5.49	696	0.80	4,806	0.21	271	175	11

**City of Sycamore - Facility #0370550
WELL 8**

DATE	HOURS RUN	WELL 8 RAW	WELL 8 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
12/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/2/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/3/2025	10	631,000	1,051.67	640,000	1,066.67	22	4.18	7	0.80	32	0.21
12/4/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/5/2025	10	651,000	1,085.00	660,000	1,100.00	23	4.24	8	0.83	34	0.21
12/6/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/7/2025	10	605,000	1,008.33	614,000	1,023.33	21	4.16	7	0.81	31	0.21
12/8/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/9/2025	10	632,000	1,053.33	641,000	1,068.33	22	4.17	6	0.76	33	0.21
12/10/2025	12	774,000	1,075.00	786,000	1,091.67	26	4.03	9	0.82	39	0.21
12/11/2025	7	475,000	1,130.95	481,000	1,145.24	15	3.79	6	0.84	26	0.22
12/12/2025	4	221,000	920.83	224,000	933.33	9	4.88	2	0.75	11	0.20
12/13/2025	5	302,000	1,006.67	307,000	1,023.33	10	3.97	4	0.86	15	0.20
12/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/15/2025	10	632,000	1,053.33	641,000	1,068.33	23	4.36	6	0.76	34	0.22
12/16/2025	2	157,000	1,308.33	160,000	1,333.33	6	4.58	3	1.02	8	0.21
12/17/2025	7	400,000	952.38	406,000	966.67	13	3.90	4	0.77	21	0.21
12/18/2025	6	379,000	1,052.78	384,000	1,066.67	14	4.43	5	0.86	20	0.22
12/19/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/20/2025	12	741,000	1,029.17	747,000	1,037.50	27	4.37	8	0.80	34	0.19
12/21/2025	9	612,000	1,133.33	626,000	1,159.26	20	3.92	7	0.81	32	0.21
12/22/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/23/2025	7	347,000	826.19	351,000	835.71	12	4.15	4	0.81	17	0.20
12/24/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/25/2025	4	347,000	1,445.83	353,000	1,470.83	10	3.46	3	0.73	13	0.15
12/26/2025	8	451,000	939.58	458,000	954.17	14	3.72	5	0.80	23	0.21
12/27/2025	1	66,000	1,100.00	67,000	1,116.67	2	3.63	1	0.91	3	0.19
12/28/2025	2	148,000	1,233.33	150,000	1,250.00	6	4.86	1	0.68	8	0.22
12/29/2025	10	630,000	1,050.00	639,000	1,065.00	32	6.09	7	0.80	32	0.21
12/30/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/31/2025	10	630,000	1,050.00	639,000	1,065.00	23	4.38	7	0.80	33	0.21
TOTALS											
MONTH	156	9,831,000	1,050.32	9,974,000	1,065.60	350	4.21	110	0.88	499	0.20
YEAR	2731	177,394,000	1,082.59	179,828,000	1,097.45	6,718	4.48	2,042	0.89	7,729	0.18

**City of Sycamore - Facility #0370550
WELL 9**

DATE	HOURS RUN	WELL 9 RAW	WELL 9 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
12/1/2025	10	616,000	1,026.67	668,000	1,113.33	32	6.23	7	0.71	31	0.21
12/2/2025	4	233,000	970.83	252,000	1,050.00	13	6.69	2	0.64	11	0.19
12/3/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/4/2025	5	338,000	1,126.67	367,000	1,223.33	17	6.03	4	0.72	16	0.19
12/5/2025	2	131,000	1,091.67	142,000	1,183.33	7	6.41	2	0.81	7	0.22
12/6/2025	10	617,000	1,028.33	669,000	1,115.00	28	5.44	6	0.67	31	0.20
12/7/2025	4	232,000	966.67	251,000	1,045.83	10	5.17	2	0.64	11	0.19
12/8/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/9/2025	4	235,000	979.17	255,000	1,062.50	11	5.61	3	0.74	12	0.21
12/10/2025	8	464,000	966.67	504,000	1,050.00	23	5.94	4	0.64	23	0.20
12/11/2025	6	414,000	1,150.00	449,000	1,247.22	21	6.08	5	0.73	21	0.21
12/12/2025	4	250,000	1,041.67	270,000	1,125.00	13	6.24	3	0.73	13	0.21
12/13/2025	6	340,000	944.44	369,000	1,025.00	18	6.35	3	0.64	17	0.20
12/14/2025	13	801,000	1,026.92	869,000	1,114.10	40	5.99	9	0.71	42	0.21
12/15/2025	5	272,000	906.67	295,000	983.33	13	5.73	4	0.79	13	0.19
12/16/2025	12	733,000	1,018.06	790,000	1,097.22	39	6.38	7	0.66	38	0.21
12/17/2025	15	914,000	1,015.56	996,000	1,106.67	45	5.90	11	0.72	49	0.22
12/18/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/19/2025	7	445,000	1,059.52	483,000	1,150.00	19	5.12	4	0.65	20	0.18
12/20/2025	3	204,000	1,133.33	221,000	1,227.78	9	5.29	22	3.17	11	0.22
12/21/2025	7	410,000	976.19	445,000	1,059.52	23	6.73	5	0.73	20	0.20
12/22/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/23/2025	10	618,000	1,030.00	670,000	1,116.67	30	5.82	6	0.67	32	0.21
12/24/2025	7	408,000	971.43	442,000	1,052.38	14	4.11	4	0.67	21	0.21
12/25/2025	10	617,000	1,028.33	670,000	1,116.67	31	6.02	7	0.71	30	0.20
12/26/2025	5	293,000	976.67	318,000	1,060.00	16	6.55	3	0.68	15	0.21
12/27/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/28/2025	5	348,000	1,160.00	378,000	1,260.00	19	6.55	4	0.71	18	0.21
12/29/2025	9	519,000	961.11	562,000	1,040.74	26	6.01	6	0.71	26	0.20
12/30/2025	7	409,000	973.81	444,000	1,057.14	18	5.28	4	0.67	22	0.22
12/31/2025	4	280,000	1,166.67	304,000	1,266.67	14	6.00	3	0.69	14	0.20
TOTALS											
MONTH	182	11,141,000	1,020.24	12,083,000	1,106.50	549	5.45	140	0.69	564	0.19
YEAR	850	49,108,000	962.90	53,304,000	1,045.18	2,376	5.34	588	0.67	2,267	0.17

**City of Sycamore - Facility #0370550
WELL 10**

DATE	HOURS RUN	WELL 10 RAW	WELL 10 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
12/1/2025	7	414,000	985.71	414,000	985.71	15	4.34	3	0.66	19	0.19
12/2/2025	7	388,000	923.81	388,000	923.81	13	4.02	4	0.74	17	0.18
12/3/2025	10	615,000	1,025.00	615,000	1,025.00	19	3.70	5	0.68	27	0.18
12/4/2025	11	649,000	983.33	649,000	983.33	19	3.51	6	0.71	30	0.19
12/5/2025	9	578,000	1,070.37	578,000	1,070.37	16	3.32	5	0.70	25	0.18
12/6/2025	7	417,000	992.86	417,000	992.86	12	3.45	3	0.66	19	0.19
12/7/2025	10	558,000	930.00	558,000	930.00	24	5.16	4	0.66	26	0.19
12/8/2025	9	543,000	1,005.56	543,000	1,005.56	22	4.86	5	0.71	25	0.19
12/9/2025	8	434,000	904.17	434,000	904.17	18	4.97	4	0.71	19	0.18
12/10/2025	2	152,000	1,266.67	152,000	1,266.67	6	4.73	1	0.64	8	0.21
12/11/2025	8	484,000	1,008.33	484,000	1,008.33	20	4.95	4	0.69	22	0.19
12/12/2025	7	394,000	938.10	394,000	938.10	16	4.87	4	0.74	17	0.18
12/13/2025	7	411,000	978.57	411,000	978.57	15	4.38	4	0.73	18	0.18
12/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/15/2025	8	412,000	858.33	412,000	858.33	16	4.66	4	0.73	20	0.20
12/16/2025	7	434,000	1,033.33	434,000	1,033.33	14	3.87	4	0.71	19	0.18
12/17/2025	3	175,000	972.22	175,000	972.22	6	4.11	1	0.62	8	0.19
12/18/2025	14	801,000	953.57	801,000	953.57	29	4.34	7	0.70	37	0.19
12/19/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
12/20/2025	4	192,000	800.00	192,000	800.00	7	4.37	1	0.60	9	0.19
12/21/2025	8	455,000	947.92	455,000	947.92	15	3.95	4	0.70	21	0.19
12/22/2025	12	651,000	904.17	651,000	904.17	23	4.24	6	0.71	31	0.19
12/23/2025	8	453,000	943.75	453,000	943.75	17	4.50	5	0.76	22	0.20
12/24/2025	3	159,000	883.33	159,000	883.33	6	4.52	2	0.81	8	0.21
12/25/2025	10	533,000	888.33	533,000	888.33	18	4.05	5	0.72	27	0.21
12/26/2025	7	331,000	788.10	331,000	788.10	12	4.35	3	0.71	17	0.21
12/27/2025	12	577,000	801.39	577,000	801.39	18	3.74	7	0.79	31	0.22
12/28/2025	6	340,000	944.44	340,000	944.44	11	3.88	3	0.70	18	0.22
12/29/2025	5	241,000	803.33	241,000	803.33	8	3.98	3	0.80	13	0.22
12/30/2025	5	236,000	786.67	236,000	786.67	9	4.57	3	0.81	14	0.24
12/31/2025	5	252,000	840.00	252,000	840.00	9	4.28	2	0.68	11	0.18
TOTALS											
MONTH	219	12,279,000	934.47	12,279,000	934.47	433	4.23	112	0.83	578	0.19
YEAR	3163	178,477,000	940.44	178,477,000	940.44	6,820	4.58	1,682	0.84	7,470	0.17

City of Sycamore
Distribution Chlorine Residuals
Facility #0370550



	Area #1		Area #2		Area # 3		Tower #1		
Date	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Comments
12/1/2025	0.73	0.66	1.01	0.86	0.94	0.83	1.24	1.06	
12/2/2025	0.81	0.76	1.09	0.91	1.01	0.91	1.21	1.10	
12/3/2025	1.01	0.94	1	0.70	1.08	0.96	1.19	1.00	
12/4/2025	0.70	0.65	0.81	0.71	0.69	0.64	1.33	1.05	
12/5/2025	0.83	0.73	0.88	0.77	0.81	0.7	1.26	1.07	
12/6/2025							1.06	0.99	
12/7/2025							1.23	1.05	
12/8/2025	1.13	0.93	1.26	1.11	1	0.92	1.27	1.02	
12/9/2025	0.99	0.86	1.26	1.06	0.98	0.86	1.17	1.03	
12/10/2025	0.88	0.78	1.35	1.08	0.93	0.8	1.2	1.03	
12/11/2025	1.16	1.00	1.38	1.15	0.75	0.65	1.12	0.95	
12/12/2025	1.09	0.98	1.29	1.10	0.82	0.74	1.07	0.99	
12/13/2025							1.22	1.03	
12/14/2025							1.29	1.11	
12/15/2025	0.84	0.74	0.82	0.76	0.88	0.71	1.3	1.10	
12/16/2025	0.96	0.85	1.06	0.95	0.73	0.63	1.17	1.00	
12/17/2025	0.96	0.84	1.06	0.93	0.81	0.64	1.1	1.00	
12/18/2025	0.81	0.74	1.06	0.87	0.76	0.61	1.27	1.04	
12/19/2025	0.90	0.78	1.16	0.98	0.76	0.66	1.19	1.07	
12/20/2025							1.2	1.00	
12/21/2025							1.12	1.00	
12/22/2025	0.70	0.59	0.82	0.75	0.76	0.69	1.13	0.93	
12/23/2025	0.85	0.78	1.19	0.99	0.88	0.77	1.18	0.95	
12/24/2025							1.16	1.00	
12/25/2025							1.39	1.19	
12/26/2025	0.88	0.76	0.81	0.72	0.67	0.58	1.09	0.88	
12/27/2025							1.21	1.05	
12/28/2025							1.65	1.34	
12/29/2025	0.88	0.72	0.78	0.59	0.67	0.56	1.17	0.99	
12/30/2025	0.77	0.69	0.89	0.79	0.64	0.52	1.72	1.53	
12/31/2025	0.90	0.81	1.02	0.85	0.68	0.6	0.99	0.89	

WELL 6

Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
12/1/2025	1.3	0.70	0.51	
12/2/2025	0.9	1.00	0.47	
12/3/2025	3.4	0.80	0.53	
12/4/2025	0.8	0.90	0.66	
12/5/2025	1.4	0.80	0.57	
12/6/2025	1.2	0.70	0.46	
12/7/2025	1.1	1.00	0.54	
12/8/2025	1.8	1.00	0.78	
12/9/2025	1.9	1.00	0.48	
12/10/2025	3.3	1.00	0.50	
12/11/2025	1.0	1.00	0.53	
12/12/2025	4.6	0.90	0.41	
12/13/2025	1.5	0.90	0.62	
12/14/2025	1.0	0.60	0.68	
12/15/2025	3.4	1.00	0.45	
12/16/2025	1.4	0.70	0.49	
12/17/2025	4.6	0.70	0.56	
12/18/2025	1.0	0.70	0.59	
12/19/2025	1.0	0.80	0.59	
12/20/2025	1.1	0.70	0.47	
12/21/2025	0.9	1.00	0.51	
12/22/2025	1.2	0.90	0.58	
12/23/2025	1.0	1.00	0.68	
12/24/2025	1.3	0.90	0.67	
12/25/2025	1.2	0.90	0.82	
12/26/2025	1.5	1.00	0.48	
12/27/2025	1.7	1.00	0.42	
12/28/2025	3.0	1.00	0.52	
12/29/2025	0.8	0.90	0.71	
12/30/2025	0.9	1.00	0.58	
12/31/2025	1.2	0.90	0.74	

WELL 7
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Iron Raw	Iron Finished	Manganese Raw	Manganese Finished	Initials
12/1/2025	2.4	0.80	0.73	0.15	0.08	0.02	0.04	
12/2/2025	1.9	0.90	0.61	NR	0.06	NR	0.02	
12/3/2025	3.2	0.80	0.68	0.27	0.00	0.03	0.03	
12/4/2025	2.1	0.80	0.53	NR	0.08	NR	0.02	
12/5/2025	2.3	0.70	0.62	NR	0.07	NR	0.03	
12/6/2025	2.0	0.70	0.51	NR	0.06	NR	0.03	
12/7/2025	1.8	0.80	0.69	NR	0.08	NR	0.02	
12/8/2025	2.0	0.80	0.48	0.24	0.03	0.01	0.04	
12/9/2025	2.2	0.80	0.45	NR	0.00	NR	0.03	
12/10/2025	1.4	0.90	0.66	NR	0.03	NR	0.03	
12/11/2025	2.0	0.70	0.35	NR	0.08	NR	0.03	
12/12/2025	2.1	0.80	0.58	NR	0.07	NR	0.04	
12/13/2025	1.8	0.70	0.75	NR	0.09	NR	0.02	
12/14/2025	2.3	0.90	0.63	NR	0.06	NR	0.04	
12/15/2025	3.0	0.90	0.27	0.22	0.00	0.01	0.03	
12/16/2025	2.1	0.80	0.95	NR	0.05	NR	0.06	
12/17/2025	2.3	0.90	0.70	NR	0.09	NR	0.09	
12/18/2025	2.2	0.90	0.52	NR	0.08	NR	0.03	
12/19/2025	1.7	0.90	0.63	NR	0.03	NR	0.03	
12/20/2025	2.0	0.70	0.29	NR	0.06	NR	0.02	
12/21/2025	1.9	0.80	0.57	NR	0.05	NR	0.03	
12/22/2025	1.4	1.00	0.53	0.45	0.00	0.02	0.04	
12/23/2025	1.7	0.80	0.54	NR	0.00	NR	0.02	
12/24/2025	2.3	1.00	0.96	NR	0.00	NR	0.02	
12/25/2025	1.6	0.90	0.68	NR	0.03	NR	0.02	
12/26/2025	2.7	0.80	0.75	0.27	0.11	0.02	0.05	
12/27/2025	2.2	1.00	0.89	NR	0.08	NR	0.04	
12/28/2025	1.3	1.00	0.93	NR	0.06	NR	0.02	
12/29/2025	2.4	0.80	0.83	0.41	0.05	0.02	0.03	
12/30/2025	2.1	0.80	0.88	NR	0.09	NR	0.03	
12/31/2025	2.7	0.90	0.51	0.21	0.04	0.02	0.02	

WELL 8 **Water Quality Control**

Date	Total Chlorine	Fluoride	Phosphate	Initials
12/1/2025	1.3	0.80	1.00	
12/2/2025	0.9	0.80	0.52	
12/3/2025	1.2	0.80	0.39	
12/4/2025	4.2	0.70	0.40	
12/5/2025	1.0	0.70	0.54	
12/6/2025	0.9	0.80	0.32	
12/7/2025	1.0	0.70	0.40	
12/8/2025	1.1	0.80	0.96	
12/9/2025	0.8	0.80	0.71	
12/10/2025	4.5	0.70	0.33	
12/11/2025	1.0	0.70	0.65	
12/12/2025	1.2	0.80	0.64	
12/13/2025	1.1	0.90	0.60	
12/14/2025	4.9	0.70	0.55	
12/15/2025	0.8	0.60	0.44	
12/16/2025	1.0	0.70	0.47	
12/17/2025	3.2	0.80	0.33	
12/18/2025	1.1	0.70	0.55	
12/19/2025	1.0	0.90	0.41	
12/20/2025	1.4	0.80	0.57	
12/21/2025	1.2	0.80	0.42	
12/22/2025	0.8	0.90	0.76	
12/23/2025	1.1	0.80	0.47	
12/24/2025	0.9	0.90	0.71	
12/25/2025	2.6	0.80	0.91	
12/26/2025	3.3	0.60	0.38	
12/27/2025	1.2	0.80	0.81	
12/28/2025	0.8	0.80	0.78	
12/29/2025	0.8	0.90	0.99	
12/30/2025	0.7	0.70	0.70	
12/31/2025	0.8	0.80	0.62	

WELL 9
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
12/1/2025	2.7	0.70	1.00	
12/2/2025	1.8	1.00	0.32	
12/3/2025	1.4	1.00	0.68	
12/4/2025	3.6	0.90	0.99	
12/5/2025	4.8	1.00	0.34	
12/6/2025	2.1	0.90	0.48	
12/7/2025	3.0	1.00	0.33	
12/8/2025	1.5	1.00	0.85	
12/9/2025	4.7	1.00	0.96	
12/10/2025	2.0	0.90	0.80	
12/11/2025	5.4	0.80	0.68	
12/12/2025	1.1	0.90	0.49	
12/13/2025	2.8	0.90	0.84	
12/14/2025	3.8	0.80	0.30	
12/15/2025	1.1	0.80	0.61	
12/16/2025	4.1	0.90	0.85	
12/17/2025	5.2	0.80	0.49	
12/18/2025	2.8	0.90	0.88	
12/19/2025	1.9	0.70	0.87	
12/20/2025	5.1	0.90	0.28	
12/21/2025	1.2	0.80	0.58	
12/22/2025	1.1	0.80	0.86	
12/23/2025	4.8	1.00	0.97	
12/24/2025	4.5	1.00	0.98	
12/25/2025	3.4	0.90	0.96	
12/26/2025	3.5	1.00	0.90	
12/27/2025	1.8	0.90	0.81	
12/28/2025	4.3	0.90	0.97	
12/29/2025	1.5	0.80	0.59	
12/30/2025	5.1	0.90	0.30	
12/31/2025	5.2	0.80	0.76	

WELL 10

Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
12/1/2025	0.7	1.00	0.59	
12/2/2025	1.1	0.80	0.68	
12/3/2025	1.3	1.00	0.49	
12/4/2025	0.8	0.90	0.54	
12/5/2025	0.9	0.80	0.69	
12/6/2025	1.0	0.90	0.61	
12/7/2025	3.7	1.00	0.70	
12/8/2025	0.8	1.00	0.48	
12/9/2025	4.8	0.70	0.30	
12/10/2025	1.0	0.80	0.68	
12/11/2025	0.9	1.00	0.72	
12/12/2025	1.0	0.80	0.68	
12/13/2025	4.5	0.80	0.29	
12/14/2025	4.8	0.90	0.28	
12/15/2025	0.8	0.80	0.54	
12/16/2025	1.0	0.90	0.42	
12/17/2025	3.8	0.90	0.32	
12/18/2025	0.8	0.80	0.68	
12/19/2025	1.0	0.80	0.49	
12/20/2025	4.0	0.90	0.39	
12/21/2025	1.2	0.90	0.30	
12/22/2025	0.9	0.90	0.55	
12/23/2025	2.2	1.00	0.51	
12/24/2025	2.1	0.90	0.70	
12/25/2025	1.1	1.00	0.71	
12/26/2025	0.8	1.00	0.60	
12/27/2025	2.8	0.90	0.44	
12/28/2025	0.9	0.90	0.58	
12/29/2025	3.7	0.80	0.42	
12/30/2025	0.7	0.90	0.55	
12/31/2025	3.7	0.70	0.49	