



City of Sycamore 2023 Sewer Lining Project

Addendum #1

February 22, 2023

2 Pages

This addendum is issued for the purpose of clarifying the intent of the contract documents and plans and also for making necessary corrections, deletions, and/or additions to the documents and plans. This addendum shall supersede any information found with the Contract Documents, Plans or previous addenda.

Each proposer shall include this document into their proposal along with entering the information and signing below.

Company

Signature of Authorized Personnel

Date

1. Bid Bond Page 2

A bid bond for 5% of the bid price is required.

2. Schedule of Prices

The attached schedule of prices shall replace Page 5-1.

3. Page 16-20 Special Provisions

Sanitary and Storm Sewer Lining within the Downtown area as identified by Locations 1-11 shall conform to the original requirements for Sanitary and Storm Sewer Lining and are now identified as "Pressure Rated" within the Schedule of Prices.

All other locations are identified as standard are not required to be pressure tested.

Storm Sewers can be visually inspected for the post video inspection.

RETURN WITH BID

SCHEDULE OF PRICES

County DEKALB
 Local Public Agency SYCAMORE
 Section NA
 Route VARIOUS STREETS

Schedule for Multiple Bids

Combination Letter	Sections Included in Combinations	Total

Schedule for Single Bid

(For complete information covering these items, see plans and specifications)

Bidder's Proposal for making Entire Improvements

Item No.	Items	Unit	Quantity	Unit Price	Total
1	Traffic Control & Protection	L.S.	1		
2	Televise, Clean & Line Sanitary Sewers, 8" - Pressure Rated	L.F.	46		
3	Televise, Clean & Line Sanitary Sewers, 8" -Standard	L.F.	1240		
4	Televise, Clean & Line Sanitary Sewers, 10" - Pressure Rated	L.F.	521		
6	Televise, Clean & Line Sanitary Sewers, 12" - Pressure Rated	L.F.	152		
7	Televise, Clean & Line Sanitary Sewers, 12" - Standard	L.F.	1128		
8	Televise, Clean & Line Sanitary Sewers, 15"- Pressure Rated	L.F.	319		
10	Televise, Clean & Line Sanitary Sewers, 18"- Pressure Rated	L.F.	659		
12	Televise, Clean & Line Storm Sewers, 12" - Pressure Rated	L.F.	109		
13	Televise, Clean & Line Storm Sewers, 18" - Pressure Rated	L.F.	133		
14	Reinstate Laterals	EACH	56		
15	Cut Protruding Taps	EACH	10		