

**Sycamore, IL**  
**750,000 Gallon Toroellipse**  
**Exterior Repaint with Containment**  
**Wet Interior Repaint**  
**and Miscellaneous Repairs**  
**13-19-12-01-21**  
**October 28, 2021**  
**Addendum No. 2**

All General Conditions and Information for Bidders shall apply. The following changes have been made in the specifications:

1. Clarification: The exterior coating system is to have a zinc primer. The coating system is to be one of the following (replace Section 09 97 13.23.14 Part 2.01C is to be replaced with the following:

C. Approved suppliers and systems:

<u>Manufacturer</u>	<u>System</u>
Tnemec	90-97/N69/1095/V700.
Induron	Indurazinc MC-67/PE-70/I-6600 Plus/Perma-Gloss
PPG	Amercoat 68HS/Amercoat 2/Pitthane Ultra/ Cora Flon ADS
Sherwin Williams	Corothane I galvapak/Macropoxy 646/Acrolon Ultra / Fluorokem HS

Acknowledge this Addendum per Page 1 of the Bid Agreement Form.